

Fire/Smoke Separations



Fire/Smoke Separations



- **Must be Maintained**

(IFC 703.1)

- **Testing**

- Fire Doors-Horizontal and Vertical Sliding and Rolling

(IFC 703.4)

- » Tested Annually

- Smokeproof Enclosures

- » Semiannual testing required-includes smoke dampers, door closures, etc.

(NFPA 101, Sec. 7.2.3.13)