

# Exit Signs



# Exit Signs



- **Must be Illuminated or Self-luminous.**
  - 90 minutes battery backup (60 for existing) (IFC 1011; 1026.3,4)
- **Readily Visible from any Direction**
- **Access to Exits Marked**
  - Where exit or path of egress travel is not immediately visible to the occupants
- **Not required:** (IFC 1011.1)
  - In rooms or areas which require only one exit
  - Main exterior exit doors
- **Testing (Backup Power)** (NFPA 101, Sec. 7.9.3)
  - 30-day intervals for not less than 30 seconds
  - Annually for not less than 90 minutes