

## Bev A. Power

---

**From:** Sue A. McKenna  
**Sent:** Friday, April 14, 2017 10:03 AM  
**To:** Bev A. Power  
**Subject:** CAPRA 8.5

### Jackson Pool Emergency Plan

The City does not approve the Emergency Plan for Jackson pool it is required by the State of Oregon Health Authority under Oregon Administrative Rules Chapter 333-Division 60 Public Swimming Pools page 36, (4) Emergency Plans

The Jackson County Health Department inspects Jackson Pool yearly to make sure we are in compliance with all State Regulations. Anything that does not meet the State Health requirements is listed on the annual inspection report, the most recent inspection report is provided.

*Dave Martin*

*Dave.C.Martin@state.or.us*

*971-673-3283*

# Oregon Health Authority

## Public Health Division

---

---

### Oregon Administrative Rules

### Chapter 333 – Division 60

### Public Swimming Pools

---

---

(F) A policy must be developed for the use of the AED, including the need to contact 911 as soon as possible after identifying the incident. This policy should be made available to pool staff and must be posted with the AED.

(4) EMERGENCY PLANS. Every general-use public pool must develop emergency plans including but not limited to:

- (a) Injuries, swimmers in trouble, drownings;
- (b) Equipment breakdowns;
- (c) Chemical release;
- (d) Severe Weather;
- (e) Fire; and
- (f) Threats to personnel, patrons, or the facility.

(5) LIFELINES. The lifeline separating the shallow and deep areas must be kept in good repair.

- (a) Keep the lifeline in place at all times, except during an event or activity when the lifeline becomes an obstruction.
- (b) Separation Areas. Keep lifelines separating slide and waterslide plunge areas from the rest of the pool in place at all times the slide or waterslide is in use.

(6) STARTING BLOCKS AND COMPETITIVE USE. Starting blocks may be used for diving only during supervised competition swimming, training, or instruction. When not in use remove or make the blocks inaccessible. Starting blocks for new or renovated pools must be installed in areas with at least five feet (1525 mm) of water depth. Existing blocks may be used according to the following conditions:

- (a) Water less than three feet six inches (1070 mm): Swimmers start in the water.
- (b) Water three feet six inches (1070 mm) but less than four feet (1220 mm) deep: Swimmers start from the deck or in the water, diving blocks are not allowed; For diving entries from the deck, the deck may be no more than six inches (150 mm) above the water surface.
- (c) Water four feet (1220 mm) but less than five feet (1525 mm) deep: Diving entries may be from elevations up to 18 inches (450 mm) above the water surface;
- (d) Water five feet or greater in depth: Diving entries may be made from up to 30 inches (750 mm) above the water surface.

(7) SECURITY. The operator must check and maintain all gates, doors, and windows into the pool area to assure proper operation in compliance with OAR 333-060-0105. Lock and secure the pool area when it is not open for use. Patrons may not have access to the pool when it is not open for use.

(a) Fire Exiting. Fire exiting from other parts of a facility through the pool is not allowed. Fire exiting may be provided through the pool area only for the pool dressing/toilet/shower facilities, pool program areas and pool equipment and storage areas as necessary.

(A) The pool operator must equip designated fire exit doors and gates with panic hardware in compliance with the **Oregon Uniform Fire Code (2007)**. Design and install panic hardware to protect against access to the hardware from outside the pool area.

(B) Existing non-compliant pools must notify and consult with the Division or agent about non-compliant fire-exit pathways through the pool area. Each situation will be reviewed by the Division or agent, in consultation with the local fire protection agency.

POOL PROGRAM INSPECTION REPORT

Jackson Co Environmental Public Health 1005 E Main St. Medford, OR 97504  
(541) 774-8206

Owner Name:  
CITY OF MEDFORD - CITY MANAGER  
JACKSON PARK POOL  
815 SUMMIT AVE.  
  
MEDFORD, OR 97501

Inspection Type: ANNUAL  
Inspection Result: COMPLD  
Establishment #: 1541024 Area: 60  
Units: 0  
County: 15

JACKSON PARK POOL  
FACILITIES MANAGMENT DIVISION  
411 W. 8TH ST.  
MEDFORD, OR 97501

Phone:  
Inspector: Chad Petersen, REHS  
Start Date/Time: 08/24/2016 at 3:23:09 PM

NOTICE OF INSPECTION: AN INSPECTION OF THE ABOVE-NAMED FACILITY WAS CONDUCTED ON THIS DATE TO ASCERTAIN COMPLIANCE WITH OR 448.005- 448.090 AND RULES OF THE OREGON HEALTH AUTHORITY PERTAINING TO PUBLIC SWIMMING POOLS AND PUBLIC SPA POOLS. FAILURE TO CORRECT ITEMS LISTED BELOW MAY RESULT IN SUSPENSION, REVOCATION OR DENIAL OF THE PERMIT OR LICENSE ISSUED UNDER ORS 448.030 or 448.035.


NO VIOLATIONS NOTED AT THIS DATE.


Free Chlorine (0.8-5.0 ppm):	5.0	Bromine (3.0-8.0 ppm):	Temperature(F):		
Combined Chlorine (0-.5 ppm):	0.2	Cyanuric Acid (0-150 ppm):	Clarity (Y/N):	Y	
Total Alkalinity (80-200 ppm):	90	Hardness (175-400 ppm):	pH (7.2-7.6):	7.2	
Inlet Pressure:	12	Outlet Pressure:	8	Flow Rate:	700
ORP mVolts (750 mVolts for Cl- and 700 mVolts for Br- ):			700		

Site Report Generated: 08/24/2016 3:25:12 PM

POOL NOTICES: All public pools should now be in compliance with the Virginia Graeme Baker Pool and Spa Safety Act. All ADA Title II and Title III pools should be in compliance with the 2010 handicapped accessibility guidelines. We do not enforce these federal requirements, but you still need to comply.

In Oregon, the law allows a mother to breastfeed their child in public places; including your pool. Information has been mailed to every public pool in Oregon. Please help protect that right.

  
\_\_\_\_\_  
Person In Charge

  
\_\_\_\_\_  
Inspection By: Chad Petersen, REHS